



Lincoln Trail

Area Development District
~ established 1968 ~

750 S. Provident Way • Elizabethtown, KY 42701
Phone: 270-769-2393 • TDD: 800-247-2510 • Fax: 270-769-2993
Equal Opportunity Employer M/F/D/V/SO

Invitation for Bid: MEADE COUNTY ROAD DEPARTMENT BUILDING
BID NO: 2026-01


Date Issued: February 5, 2026

Bid Date: February 27, 2026

ADDENDUM #2 RESPONSES TO QUESTIONS:

The following information supersedes or is in addition to information released in the Contract Documents dated 2/5/2026. Each bidder shall govern their actions accordingly in the preparation of their bid.

1. Is there WWM reinforcing steel in the building slab or rebar?
 - a. **Use 6x6 w2.9/2.9 in the slab (single row)**
2. Does the slab get tied into the foundation wall with steel and if so, what size and spacing?
 - a. **The slab is independent of the foundation wall. Use this detail as an example.**



Office: (270) 769-2393 • Fax: (270) 769-2993 • E-mail: charlie@ltadd.org
Locally Based...Regionally Focused